



Reply Sheet for City of London Applications to be Reviewed by London Hydro Engineering

Date:

To: City of London Planning Division – Room 609

Attn: _____

RE: Address: _____
Applicant: _____
File/Ref #: _____

London Hydro Response:

Servicing the above proposal should present no foreseeable problems. Any new and/or relocation of existing infrastructure will be at the applicant’s expense, maintaining safe clearances from L.H. infrastructure is mandatory. Note: Transformation lead times are minimum 16 weeks. Contact the Engineering Dept. to confirm requirements & availability.	
This site is presently serviced by London Hydro. Contact the Engineering Dept. if a service upgrade is required to facilitate the new building. Any new and/or relocation of existing infrastructure will be at the applicant’s expense, maintaining safe clearances from L.H. infrastructure is mandatory. Note: Transformation lead times are minimum 16 weeks. Contact the Engineering Dept. to confirm requirements & availability.	
Servicing the above proposal should present no foreseeable problems. Any new and/or relocation of existing infrastructure will be at the applicant’s expense, maintaining safe clearances from L.H. infrastructure is mandatory. A blanket easement will be required. Note: Transformation lead times are minimum 16 weeks. Contact Engineering Dept. to confirm requirements & availability.	
London Hydro has no objection to this proposal or possible official plan and/or zoning amendment. Any new or relocation of the existing service will be at the expense of the owner.	
London Hydro has no objection to this proposal or possible official plan and/or zoning amendment. However, London Hydro will require a blanket easement.	

Signed: _____

Hans Schreff
 Manager - Developer & Operations Support,
 Engineering & Operations Administration Dept.
 519-661-5800 ext. 5014

Committee of
Adjustment

Notice of
Application

Site Plan
Consultation

Site Plan
Application