

For discussion

- a. Do we want to edit this section before sending it to staff?

4.5.7 Security Lighting

Lighting to ensure the safety of pedestrians shall be used as required. Light fixtures for this purpose shall:

- Reduce brightness contrast
- Ensure no light is directed 90° above the horizontal
- Employ motion sensors (Section 4.2, bullet 5, option B)

These guidelines shall apply to all pedestrian trafficked areas and will be included in the site/lot lumen allowance.

- b. Once we have a final draft:

The fourth draft be referred to staff for review, it being noted that three advisory committees recommend staff prepare a version for Council consideration.

It further being noted that section 4.1 contemplates a light curfew for London. The specific times have been left blank. A suggested light curfew would be from 1 am to 7 am.

Commented [1]:
Concerned about impact on safety or perception of safety.